

DWG. NO.	096-6130		
REVISIONS			
SYM.	E.C.O.	DATE	APVD.
RELEASED TO PROD.			

DO NOT USE THIS SURFACE FOR CABLE ENTRY.  
DOING SO WILL VOID THE WARRANTY.

CONDUIT LANDING SURFACE  
BOTH SIDES.

NOTE:  
ADD 4.0 LBS TO STANDARD UPS WEIGHT.  
USED WITH FIRSTLINE PLT, FIRSTLINE XD 3x3, FIRSTLINE XD 3x1.

\*REAR CLEARANCE MUST BE 4" [101.6] FROM REAR OF UPS.

UNLESS OTHERWISE SPECIFIED, TOLERANCE IS ±		UNITS		TITLE:	
DECIMALS	HOLES	ANGLES	DRAFT	FIRSTLINE PLT	
.XX	.010	1°	1-1/2°	BE REAR WIRING OPTION	
.XXX	.005			FLP-T-BE 10-40 KVA	
MATERIAL:		ALL DIMENSIONS APPLY AFTER PLATING		DRAWN BY: T. SEARS	
				DATE: 01/04/19	
				FIRST USED ON: UL924	
				DO NOT SCALE DWG.	
				CHECKER: S. SMITH	
				DATE: 01/04/19	
				WEIGHT APPROX.:	
				CAGE CODE: 83008	
				SCALE: 1/8	
				SHEET 1 OF 1	
				DWG. NO. 096-6130	
				D	

The information and design disclosed herein was originated by and is the property of STACO ENERGY PRODUCTS CO., which reserves all patent, proprietary, design, manufacturing, reproduction, use and sale rights thereon, and to any article disclosed therein except to the extent rights are expressly granted to others. The foregoing does not apply to vendor proprietary parts.



A Components Corporation of America Company  
2425 Technical Drive, Mansfield, Ohio 44842 USA

